

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 116595  
Permit No. \_\_\_\_\_  
Basin 049

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67595

1. OWNER ROBIN POST  
MAILING ADDRESS 372 MOUNTAIN CITY HWY UNIT 6  
ELKO, NV. 89801

ADDRESS AT WELL LOCATION 1880 CANYON DR.

Subdivision Name: CRESTVIEW County: ELKO

2. LOCATION NW 1/4 NW 1/4 Sec 7 T 34N N/S R 55 E  
PERMIT/WAIVER No. 083-001-009  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude UTM E 11T 0598453  NAD 27  
Longitude N 4522727  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
EXISTING WELL LOG # 29262				
GRAVEL & SAND	X	581	610	29
BLACK SHALE		610	620	10
GREEN & BLACK SHALE		620	665	45
LIGHT GRAY SHALE	X	665	680	15
BLACK SHALE		680	690	10

*\* Deepens well log # 29262*

WELDED A 5" PLATE WITH A  
1 1/4" HOLE IN CENTER ON  
BOTTOM OF LINER

9. WELL CONSTRUCTION

Depth Drilled	690	Feet	Depth Cased	690	Feet
---------------	-----	------	-------------	-----	------

HOLE DIAMETER (BIT SIZE)

	From	To		
	6	Inches	581	Feet
		Inches		Feet
		Inches		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	32.53	.71	570	690

Perforations:

Type of perforation PLASMA CUT  
Size of perforation 3/16" X 3", 5 ROWS

From	570	feet to	610	feet
From	670	feet to	690	feet
From		feet to		feet
From		feet to		feet
From		feet to		feet

Annular Seal:  Yes  No

<input type="checkbox"/> Neat Cement	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack:  Yes  No to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

Bentonite Chips:  Yes  No to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 13-Dec 20 11  
Date completed: 15-Dec 20 11

7. Water Level  
Static water level: 410 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: 65 °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
BLOW TEST	40		4 HOURS

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC.  
Contractor

Address P. O. BOX 850  
Contractor

ELKO, NV 89803

Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 020582

Nevada driller's license number issued by the  
Division of Water Resources, the on-site driller 1408

Signed [Signature]  
By driller performing actual drilling on site or contractor

Date 12/16/2011

(Rev. 05-08)

40.851589°N  
115.832015°W  
NA027

USE ADDITIONAL SHEETS IF NECESSARY