STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116597
Permit No.
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 67783

1. OWNER PHIL BJORK (philip & Deanna Bjork)
MAILING ADDRESS 770 JACKS VALLEY RD
CARSON CITY, NV 89705

ADDRESS AT WELL LOCATION 770 JACKS VALLEY RD
CARSON CITY, NV 89705
Subdivision Name: County: Carson City

2. LOCATION NE ¼ NE ¼ Sec 12 T 14N N/S R 19 E
PERMIT/WAIVER No. DOM12-02 (Issued by Water Resources) 1419-12-510-014 (Parcel No.)
Latitude 39.09692*N
Longitude 119.79106*W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| OLD WELL 6 5/8 | | 0 | 220 | 220 |
| DG SANDS | | 220 | 235 | 15 |
| REDDISH SANDS | | 235 | 258 | 23 |
| COURSE DG SANDS | XX | 258 | 300 | 42 |
| Deepening of well log # 105750 | | | | |

RECEIVED 2012 JUN 12 AM 10:38 STATE ENGINEERS OFFICE

Date started: 21-May, 20 12
Date completed: 24-May, 20 12

9. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 6 | Inches | 220 | Feet | 300 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 5 | 3.81 | .219 | 100 | 300 |

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation .032
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No to ☐ Pumped ☐ Poured
Type: PEAT GRAVEL
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 80 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | 50 | 3 HRS |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 05/28/2012

(Rev. 05-08) USE ADDITIONAL SHEETS IF NECESSARY

39.097011°N
119.790046°W NAD27