"Lot 8"

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT # 3

OFFICE USE ONLY
Log No. 116632
Permit No.
Basin 064

69410

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Richard (and Christina) Ripley
MAILING ADDRESS 470 26Th ST
Battle Mtn NV 89820

NOTICE OF INTENT NO.
ADDRESS AT WELL LOCATION 480-26 Th ST.
Battle Mtn NV 89820
Subdivision Name: County: Lander

2. LOCATION NW ¼ SW ¼ Sec 24 T 32 N/S R 44 E
PERMIT/WAIVER No. 011-040-07
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 502206 ☒ NAD 27
N 4497723 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
yellow clay		5	40	35
Blue clay		40	92	52
Tan clay with sand & Gravel		92	120	28

Date started: 7-18, 20 12
Date completed: 7-19, 20 12

RECEIVED 2012 JUL 24 AM 11:01 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	120

Perforations:
Type of perforation Sawed Cut (PVC)
Size of perforation
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 5 to 60 ☐ Pumped ☒ Poured
☐ [redacted] to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 90 to 120 ☐ Pumped ☒ Poured
Type: 3/8 - 1/4
Bentonite Chips: ☒ Yes ☐ No 60 to 90 ☐ Pumped ☒ Poured
Type: 3/8

7. Water Level
Static water level: 42 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Rotary	75+	UNK	3 Hrs

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LBJ DRILLING & PUMP COMPANY, INC. (Contractor)
Address P.O. BOX 902 - Winnemucca, NV 89446 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 0009605A
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1807
Signed Joe Boggio (By driller performing actual drilling on site or contractor) Joe Boggio
Date

(Rev. 06-04) USE ADDITIONAL SHEETS IF NECESSARY

40.632244°N
116.973915°W
NAD27