

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY

Log No. 116666

Permit No. _____

Basin CB7

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 68344

1 OWNER Washoe County Department of Water Resources
MAILING ADDRESS 4930 Energy Way
NW Reno, NV, 89502

ADDRESS AT WELL LOCATION Intersection of Washington & West 3rd st.
Reno, NV.
Subdivision Name: _____ County: Washoe

2 LOCATION SW 1/4 NW 1/4 Sec 11 T 19N N/S R 19 E
PERMIT/WAIVER No. _____
Issued by Water Resources Parcel No.

Latitude 39 31.607N UTM E NAD 27
Longitude 119 49.381W N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? _____
If yes, what is replacement well NOI? _____
Is there an existing well log? yes
If yes, what is NDWR well log #? 88850

4 EXISTING WELL CONSTRUCTION
Depth Drilled 35' Feet Depth Cased 35' Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 2 | | sch. 40 pvc | 0 | 35 |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:

| Type of perforation | Size of perforation | From | To |
|---------------------|---------------------|---------|---------|
| slotted | 0.02 | 25 feet | 35 feet |
| | | | |
| | | | |
| | | | |
| | | | |

Additional Perforations:

Type of perforator used:

| From | To | Number of perfs per linear foot |
|------|----|---------------------------------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

5 WATER LEVEL
Static water level 33.4 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

6 Additional Notes or Comments
Installed 3/4" tremme pipe to 34', mixed approx. 2 bags of Portland cement with 10 gal of water and pumped from bottom of well to surface

| From | To | Material Used | neat cement | Pumped | Poured |
|------|---------|---------------|-------------------------------------|--------------------------|--------------------------|
| 35 | surface | neat cement | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Plugs Well log # 88850
NAD 27
39.526873° N
119.821991° W

Neat Cement Fluid Weight _____ lbs/gal
Bentonite Grout _____ % bentonite
Date Started 4/17/2013
Date Completed 4/17/2013

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Carson Pump, LLC
Contractor

Address P.O. Box 20159
Contractor

Carson City, NV. 89721

Nevada contractor's license number _____
issued by the State Contractor's Board 39920

Nevada driller's license number issued by the _____
Division of Water Resources, the on-site driller 1482

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 5/6/2013