

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116675
Permit No. _____
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70131

1. OWNER David Thomas ADDRESS AT WELL LOCATION 6555 Supreme Ct.
MAILING ADDRESS 6555 Supreme Ct. Winnemucca NV 89445
Subdivision Name: Sonoma Ranches County: Humboldt

2. LOCATION NE 1/4 SE 1/4 Sec 7 T 35.0 S R 38 E Latitude N 40° 55.287 UTM E NAD 27
PERMIT/WAIVER No. 1010-482-35 Longitude W 117° 14.389 N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders, clay sand	NO	0	60	60
Cobbles, gravel		60	160	100
Hard black limestone	NO	160	210	50
Medium brown limestone	YES	210	240	30
Cobbles, gravel sand	YES	240	300	60

9. WELL CONSTRUCTION

Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>1 7/8</u>	<u>0</u>	<u>300</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>Steel</u>	<u>0.188</u>	<u>0</u>	<u>20</u>
<u>6 3/4</u>	<u>PVC</u>	<u>sched 40</u>	<u>20</u>	<u>300</u>

Perforations:

Type of perforation slot

Size of perforation .20

From 260 feet to 300 feet

Annular Seal: Yes No

Neat Cement 0 to 50 Pumped Poured

Cement Grout Pumped Poured

Concrete Grout Pumped Poured

≥30% Bentonite Grout Pumped Poured

Gravel Pack: Yes No 50 to 300 Pumped Poured

Type: 3/8 Pea gravel

Bentonite Chips: Yes No Pumped Poured

Date started: 5-7 :20 13

Date completed: 5-7 :20 13

7. Water Level

Static water level: 2.22 feet below land surface

Artesian Flow: _____ G.P.M. _____ P.S.I.

Water Temperature: Cold °F

Quality: Clear

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<u>25</u>	<u>NA</u>	<u>6</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Allied Drilling Inc. Contractor

Address 5140 Jungo Rd. Contractor
Winnemucca NV 89445

Nevada contractor's license number _____

issued by the State Contractor's Board 26778

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563

Signed [Signature]
By driller performing actual drilling on-site or contractor

Date 5-7-13