STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116684
Permit No. 82712T
Basin 137B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67427

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480
Round Mountain, Nevada, 89045

ADDRESS AT WELL LOCATION Round Mountain Pit
Well Name:DW-67A

2. LOCATION NW ¼ NE ¼ Sec 30 T 10N N/S R 44 E
PERMIT/WAIVER No. 82712T ~~N/A-W-6714~~ N/A
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 492977.450 ☑ NAD 27
N 4283547.481 ☐ NAD 83/WGS 84
Subdivision Name: N/A *County:* Nye

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ~~☑ Other...~~

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Densely Welded Tuff (type1)	2ft.	0	140	140
Paleozoic Metasediments(type4)		140	810	670

RECEIVED 2013 MAY 31 AM 10:52 STATE ENGINEERS OFFICE

NAD 27
38.70239 3°N
117.0460760°W

Date started 29-Apr , 20 13
Date completed 12-May , 20 13

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
airlift 790'	83	625	4.5 hr.

8. WELL CONSTRUCTION
Depth Drilled 810 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
26	Inches	0	Feet	35	Feet
19	Inches	35	Feet	800	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
22	86.61	.375	0	35
12.75	33.375	.25	+2	800
2.375	4.38	.1875	+1	740

Perforations:
Type of perforation louvered (sounder is slotted .125)
Size of perforation 0.125
From 120 feet to 720 feet
From feet to feet
From feet to feet
From feet to feet
From (sounder)640 feet to 740 feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 20
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 100 feet to.. 810 feet

9. WATER LEVEL
Static water level 2ft. feet below land surface
Artesian flow No G.P.M N/A P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name National EWP
Contractor
Address 580 West Silver Street
Contractor
Elko Nevada 89801
Nevada contractor's license number issued by the *State Contractor's Board* 00075355
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2457
Signed
By driller performing actual drilling on site or contractor
Date May 13,2013

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY