

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116694
Permit No. _____
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70266

1. OWNER ARNOLD BECK CONSTRUCTION INC
MAILING ADDRESS 247 GREENCREST DR
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 950 DRY CREEK TRAIL
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION NE 1/4 NW 1/4 Sec 33 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-09Q-013
Issued by Water Resources Parcel No. _____

Latitude UTM E 11T 0602153 NAD 27
Longitude N 4516278 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GRAVEL & SAND w/ BOULDERS		0	20	20
FINE GRAVEL & SAND		20	40	20
GREEN CLAY w/ SAND		40	80	40
GREY BLACK CLAY	X	80	240	160
BLACK SANDSTONE	XXX	240	280	40
1ST WATER	X	240		
2ND WATER	XXX	270		

RECEIVED
2013 MAY 28 AM 11:18
STATE ENGINEERS OFFICE

NAD 27
40.79 3052°N
115.78 9186°W

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
280		280	

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
10 5/8	0	280	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+1 1/2	280

Perforations:

Type of perforation PLASMA CUT
Size of perforation 3/16" X 4", 7 ROWS

From	feet to	feet	feet
260	280		

Annular Seal: Yes No

<input checked="" type="checkbox"/> Neat Cement	4 to 25	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack: Yes No 55 to 280 Pumped Poured
Type: 3/8" WASHED PEA GRAVEL

Bentonite Chips: Yes No 25 to 55 Pumped Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 79 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: 71 °F
Quality: GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC.
Contractor
Address P. O. BOX 850
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1653
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 5/23/2013

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
AT 280'	100		1 1/2 HOURS
AT 180'	75		
AT 160'	60		
AT 120'	50		
AT 100'	20		

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY