STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116796
Permit No. 82574T / 82575T
Basin No. 153

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. ~~69279~~ 70227
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Steve Venturacci
MAILING ADDRESS 445 Venturacci Ln.
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION Diamond Valley
Eureka, NV 89316
Subdivision Name: *County:* Eureka

2. PLS LOCATION NE ¼ SE ¼ 3 Sec 23 N/S 54 E
PERMIT/WAIVER NO. 82574T/82575T
Issued by Water Resources *Current Parcel No.*

Latitude 39.90305 UTM E ☐ NAD 27
Longitude 115.86816 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☒ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☒ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Top Soil			0	10	10
Gravel			10	18	8
Gravel w/s Clay			18	60	42
Fracured Rock		X	60	165	105

NAD 27
39.903123° N
115.867269° W

Date started: 13-May, 20 13
Date completed: 16-May, 20 13

RECEIVED 2013 JUN -5 AM 11:17 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled: 165 Feet Depth Cased: 165 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	100	Feet
6.25	Inches	100	Feet	165	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	100
5	10.8	.188	25	165

PERFORATIONS:
Type of perforation: Mill Cut
Size of perforation: 0.1875
From 125 Feet To 165 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☒ Sanitary Seal 0 to 100
☒ Neat Cement 0 to 100 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

7. WATER QUALITIES
Static water level: 21 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality: unknown

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 Fallon, NV 89407 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1753
Signed: *(By driller performing actual drilling on site or contractor)*
Date: 5/21/2013

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY