

Correction

STATE OF NEVADA DIVISION OF WATER RESOURCES WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 116867
 Permit No. 68618
 Basin No. 057

PRINT OR TYPE IN BLACK INK ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69183
 WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME Ellison Ranchers-Cottonwood
 MAILING ADDRESS HC 32 Box 240
Tuscarora, NV 89834

DETAILED ADDRESS AT WELL LOCATION Antelope Valley - HC61 Box 191
Battle Mountain, NV 89820
 Subdivision Name: _____ County: Lander

2. PLS LOCATION SW $\frac{1}{4}$ NE $\frac{1}{4}$ 15 Sec 25 N/S 41 E
 PERMIT/WAIVER NO. 68618
Issued by Water Resources Current Parcel No.

Latitude 40.04021 UTM E NAD 27
 Longitude 117.34874 UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # 86368
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Corn / Ind Stock
 Test / Other Mun / QM Rec Other

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG					
Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
Clay w/s Sand			0	43	43
Sand			43	65	22
Clay w/s Sand			65	97	32
Clay			97	134	37
Gravel			134	153	19
Sand			153	164	11
Clay			164	171	7
Gravel		X	171	205	34
Sand		X	205	224	19
Clay			224	243	19
Gravel		X	243	257	14
Clay			257	283	26
Sand Stone		X	283	609	326
Clay			609	618	9
Sand		X	618	682	64
Gravel		X	682	701	19
Clay			701	723	22
Gravel		X	723	742	19
Sand		X	742	846	104
Gravel		X	846	883	37
Clay			883	915	32
Sand		X	915	1000	85

9. WELL CONSTRUCTION					
Depth Drilled:	1000	Feet	Depth Cased:	1000	Feet
HOLE DIAMETER (BIT SIZE)					
	From	To			
	36	Inches	0	Feet	50
	28	Inches	50	Feet	1000
		Inches		Feet	

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
18	58.9	.312	0	1000
30	118.76	.375	0	5
30	39.5	.109	5	45

PERFORATIONS:
 Type of perforation: Mill Cut
 Size of perforation: 1/4
 From 200 Feet To 240 Feet
 From 280 Feet To 440 Feet
 From 480 Feet To 520 Feet

ANNULAR MATERIALS
 Sanitary Seal 0 to 50
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout 0 to 50 Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips _____ to _____ Pumped Poured
 Bentonite Grout _____ to _____ Pumped Poured
 15% 20% Other, explain: _____
 Gravel Pack [> 0.2 in.] 0 to 1000 Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

Date started: 8-Apr , 20 13
 Date completed: 4/16/2013 , 20 13

7. WATER QUALITIES
 Static water level: 94 Feet below land surface
 Artesian Flow: _____ G.P.M. _____ P.S.I.
 Water Temperature: cool ° Fahrenheit
 Water Quality: unknown

8. WELL TEST DATA			
Test Method:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)		Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision. This report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Fallon, NV 89407 Contractor
 Nevada contractor's license number as issued by the State Contractor's Board: 29064
 Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2307
 Signed: Wayne Parson
By driller performing actual drilling on site or contractor
 Date 5/25/2013

