STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116883
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67520

1. OWNER DAVID HARRISON
MAILING ADDRESS 1680 TONI CT
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 1680 TONI CT
MINDEN, NV 89423
Subdivision Name: County:

2. LOCATION SE ¼ NW ¼ Sec 2 T 13N N/S R 20 E
PERMIT/WAIVER No. 1320-02-001-065
Issued by Water Resources Parcel No.

Latitude 39.02057°N
Longitude 119.70667°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 8 5/8 WELL		0	190	190
COURSE DG SANDS		190	236	46
BROWN CLAY		236	274	38
COURSE DG SANDS	X	274	315	41
SMALL DG GRAVELS	XX	315	360	45

RECEIVED 2011 JUL 27 AM 10:56 STATE ENGINEER'S OFFICE

Date started: 12-Jul, 20 11
Date completed: 15-Jul, 20 11

9. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8 1/8	Inches	190	Feet	360	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.06	.216	160	360
SDR 21				

Perforations:
Type of perforation FACTORY SLOT
Size of perforation .032
From 300 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 165 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	115	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed (By driller performing actual drilling on site or contractor)
Date 07/18/2011

(Rev. 03-08)

USE ADDITIONAL SHEETS IF NECESSARY

39.020661°N NAD27
119.705661°W