STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116884
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. ~~89675~~ 67537

1. OWNER DAVID COSCARART
MAILING ADDRESS 1710 HOID ST
NW MINDEN, NV 89423

ADDRESS AT WELL LOCATION 1710 HOID ST
MINDEN, NV 89423
Subdivision Name: ✓ County: Douglas

2. LOCATION ~~NE~~ ¼ ~~SW~~ ¼ Sec 2 T 13N N/S R 20 E
PERMIT/WAIVER No. SE 1320-02-002-026 ✓
issued by Water Resources Parcel No.

Latitude 39.01792°N
Longitude 119.70493°W
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 8 5/8 WELL		0	205	205
COURSE DG SANDS		205	273	68
BROWN CLAY		273	290	17
BROWN CLAY AND SANDS		290	310	20
DG SANDS FRACTURES	XXX	310	345	35
BROWN SILTY CLAY	X	345	360	15

* original well being deepened - unknown log

Date started: 15-Dec, 20 11
Date completed: 19-Dec, 20 11

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	205	Feet	360	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	.426	.216	200	360
SDR 21				

Perforations:
Type of perforation FACTORY MLL SLOT
Size of perforation .032
From 320 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☒ Cement Grout	0 to 50		☐ Pumped	☒ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 205 ☐ Pumped ☐ Poured
Type: PEAT GRAVEL
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 140 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	75	3 HRS
39.018011°N		NAD27
119.703921°W		Dec/Deg

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed Michael Hack (By driller performing actual drilling on site or contractor)
Date 12/20/2011

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY