STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117037
Permit No.
Basin 164A

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36623

1. OWNER Primm South Real estate Company % M Skender
MAILING ADDRESS 5420 Kictzke Ln#108
Reno, NV 89511-2063

ADDRESS AT WELL LOCATION 100 W Primm Blvd
Unincorp County
MW-3

2. LOCATION NE ¼ SW ¼ Sec 8 T 27 N/S R 59 E
PERMIT/WAIVER No. 237-08-301-002
Issued by Water Resources Parcel No.

Latitude 35 36'38.26"N
Longitude 115 23'30.84"W
UTM E
N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: *County:* Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	5	5
Silty Sand		5	10	5
Sandy Clay		10	15	5
Sandy Silt		15	30	15
Silty Sand		30	45	15
Sandy Silt		45	57	12
Silty Sand		57	100	43

DCNR/DWR/SNBO
RECEIVED
APR 04 2013

Date started 13-Mar , 20 13
Date completed 14-Mar , 20 13

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		.5

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	100 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		Sch 40	0	100

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.02
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 74
Placement Method: ☑ Pumped ☐ Poured
Gravel Packed: ☑ Yes ☐ No
From 78 feet to 100 feet

Seal Type:
☐ Neat Cement
☑ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 85.81 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling L.P. (Contractor)
Address 555 S. Harbor Blvd (Contractor)
La Habra, CA 90631
Nevada contractor's license number issued by the *State Contractor's Board* C23 0073966
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2381
Signed (By driller performing actual drilling on site or contractor)
Date 4-4-13

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY

35.610646
-115.391073 - NAD 27