STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117058
Permit No.
Basin No. 082

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67161
WELL NAME *(If applicable)*: AS-1

1. OWNER/CLIENT NAME Pyramid Lake Paiute Tribe
MAILING ADDRESS 208 Capital Hill Road
Nixon, CA 89424

DETAILED ADDRESS AT WELL LOCATION Facility ID: D-000066
5000 Highway 447 Wadsworth, NV
Subdivision Name: *County:* Washoe

2. PLS LOCATION SW ¼ NE ¼ 16 Sec 21N N/S 24 E
PERMIT/WAIVER NO. 079-180-08
Issued by Water Resources *Current Parcel No.*

Latitude 39.691272 UTM E ☐ NAD 27
Longitude -119.289308 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
Sandy silt, fine			0	10	10
Clay mix silt, light brown			10	20	10
Clay, stiff, dark brown			20	30	10
Sandy silts, fine grain, dark brown			30	40	10

NAD27
39.691361° N
119.288304° W

RECEIVED 2013 JUL 9 AM 10:45 STATE ENGINEER'S OFFICE

Date started: 19-Jun , 20 13
Date completed: 19-Jun , 20 13

9. WELL CONSTRUCTION
Depth Drilled: 40 Feet Depth Cased: 40 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	40	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 40	0	40

PERFORATIONS:
Type of perforation: Slot
Size of perforation: 0.02
From 35 Feet To 40 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☐ Sanitary Seal		to			
☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	30	☒ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	30	to	33	☐ Pumped	☒ Poured
☐ Bentonite Grout		to		☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:					
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	33	to	40	☐ Pumped	☒ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Cascade Drilling, L.P.
Contractor
Address 3000 Duluth Street West Sacramento, CA 95691
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 73966
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2467

Signed:
By driller performing actual drilling on site or contractor
Date: 7/15/13

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY