STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117211
Permit No.
Basin 162

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36244

1. OWNER BPVL1 LLC
MAILING ADDRESS 5955 EDMOND ST
LAS VEGAS NV 89118-2856

ADDRESS AT WELL LOCATION 556 N BLAGG RD
PAHRUMP NV
Subdivision Name: County: NYE

2. LOCATION SE ¼ NE ¼ Sec 9 T 20S N/S R 53 E
PERMIT/WAIVER No. R-1600 35-111-12
Issued by Water Resources Parcel No.

Latitude N 36° 13'37.0" UTM E ☐ NAD 27
Longitude W 116° 01'03.8" N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other PLUG

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PUNCH HOLE IN BOTTOM CAP				
PUMP IN 12 SACKS OF NEAT				
CEMENT USING 2" TRIMIE LINE				
& GEO LOOP GROUT PUMP.				
PULL SURFACE STEEL				
SLEEVE & CUT OFF 3' BELOW				

DCNR/DWR/SNBO
RECEIVED
APR 09 2013

Date started: 20-Mar , 20 13
Date completed: 20-Mar , 20 13

9. WELL CONSTRUCTION
Depth Drilled 61 Feet Depth Cased 61 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING	Inches	0	Feet	61	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	EXISTING	4" MO WELL	0	61

Perforations:
Type of perforation
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☒ Neat Cement 0 to 61 ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING
Contractor
Address 1220 MANSE RD
Contractor
PAHRUMP NV 89048
Nevada contractor's license number issued by the *State Contractor's Board* 4733
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2485
Signed
By driller performing actual drilling on site or contractor
Date 4/5/2013

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36.2269842 NAD 27
-116.0168617