STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117249
Permit No. 60521
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35260

1. OWNER Las Vegas Valley Water District
MAILING ADDRESS 1001 So. Valley View
Las Vegas NV, 89153

ADDRESS AT WELL LOCATION 6401 W. Oakley Bvld.
Subdivision Name:
County: Clark

2. LOCATION NE ¼ SW ¼ Sec 2 T 21 N(S) R 60 E
PERMIT/WAIVER No. 60521 (Issued by Water Resources) 163-02-302-001 (Parcel No.)

Latitude 36° 9' 2.69" N
Longitude 115° 14' 7.02" W
UTM E 658501.439 N 4002039.250
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Installed patches				
1st patch 4'		600	604	
2nd patch 4'		639	643	

DCNR/DWR/SNBC RECEIVED APR 02 2013

Date started: 02-15, 20 13
Date completed: 04-02, 20 13

7. Water Level
Static water level: 290' feet below land surface
Artesian Flow: N/A G.P.M. P.S.I.
Water Temperature: N/A °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 1040 Feet Depth Cased 1020 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
48	Inches	0	Feet	80	Feet
18	Inches	80	Feet	1098	Feet
34	Inches	80	Feet	1040	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
36"		.375	0	80
24"		.375	0	520
24		.375	600	640
24"		.375	1020	1040

Perforations:
Type of perforation: wire wrap screen S.S.
Size of perforation: .100 slot

From 520	feet to 600	feet
From 640	feet to 1000	feet
From	feet to	feet
From	feet to	feet
From	feet to	feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 295	☒ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout		to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 300 to 1020 ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Las Vegas Water District
Address (Contractor) 1001 So. Valley View
Las Vegas NV, 89153
Nevada contractor's license number issued by the State Contractor's Board N/A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2248 LTD
Signed (By driller performing actual drilling on-site or contractor)
Date April 2, 2013

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36.1507779 NAD27
-115.234448

(NSPO 3-08)

(O) 627