STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117266
Permit No. 24053
Basin No. 212

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34363
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME County of Clark
MAILING ADDRESS 500 Grand CENTRAL PKWY Las Vegas NV 89155

DETAILED ADDRESS AT WELL LOCATION Sunset Park
Subdivision Name: *County:*

2. PLS LOCATION NW¼ SW ¼ 1 Sec 22 N(S) 61 E
PERMIT/WAIVER NO. 24053 *Issued by Water Resources* 177-01-301-001 *Current Parcel No.*

Latitude 36.063116 UTM E ☐ NAD 27
Longitude -115.118011 UTM N ☒ NAD 83/WGS 84
DSB

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☒ Recondition: Original well log #

4. PROPOSED USE Rec
☐ Domestic ☒ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
RAN 10 inch					
Liner in and					
~~the~~ removed					
gravel where					
casing had failed					
to get liner					
below casing					
failure.					

DCNR/DWR/SNDO RECEIVED MAY 23 2013

Date started: 4-29 , 20 13
Date completed: 4-20 , 20 13

9. WELL CONSTRUCTION
Depth Drilled: Feet Depth Cased: 268 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
	Inches		Feet		Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"	PVC	40	0	268

PERFORATIONS:
Type of perforation: Machines
Size of perforation: 48 x 6" x 6 around
From 10' Feet To 268' Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☐ Sanitary Seal to
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

7. WATER QUALITIES
Static water level: 17 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Water Well Services Inc
Contractor
Address 6455 W Gary Las Vegas NV
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board* 22311C
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 2097
Signed:
By driller performing actual drilling on site or contractor
Date: 5-21-13

(Rev. 08-12) USE ADDITIONAL SHEETS IF NECESSARY

36.0631423 NAD 27
-115.1141814