STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117291
Permit No. 76820
Basin 179

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69639

1. OWNER Sam Henriod
MAILING ADDRESS HC-33 Box 33897
Ely, NV 89010

ADDRESS AT WELL LOCATION Hwy 93 Logic Junction
Subdivision Name:
County: Whitepine

2. LOCATION NE ¼ SW ¼ Sec 33 T 26 N/S R 65 E
PERMIT/WAIVER No. 76820 R-739
Issued by Water Resources
Parcel No.

Latitude N 40° 05.030
Longitude W 114.38840
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other Well Abandon

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Mud.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Intered Well With Tools				
Cleaned out To 482'				
Casing Was Rusted thin				
Large Rust Scale Was				
Cleaned Out With Sand				
And Silt. Used 12¼"				
dia Bit To Clean Out.				
Used Water as a flood				
To Clean Out.				
Waiver R-739				
Plugs well log # 10191	Replaced by 116621			
NAD27 40.083901°N				
114.646477°W				

Date started: July 10/13 Set up, 20
Date completed: July 11/13 Finished, 20

9. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12¼ Bit	Inches	0	Feet	482'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"		3/16"	0	482'
	old	Log Showed.		

Perforations:
Type of perforation
Size of perforation
From 0' feet to 27' Air Perfed
From With Bolt 3/16 x 1½ 8 Rows feet
From feet to feet
From 27' ft feet to 480 Was feet
From Torch Cut By Old Log feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement 0 to 50' ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout 50' to 482' ☒ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 32' feet below land surface
Artesian Flow: NO G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE
2013 JUL 30 AM 10:43
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Teach Drilling Inc
Contractor
Address PO Box 599
Contractor
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876-1740
Signed Nathaniel L. Teach
By driller performing actual drilling on-site or contractor
Date 7/25/13

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(O) 627