STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117325
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65857

1. OWNER Steve Hancock
MAILING ADDRESS 3840 Alcorn Rd Fallon Nv.
ADDRESS AT WELL LOCATION 3840 Alcorn Rd. Fallon Nv. 89406 (Alcorn Rd.) (Fallon, NV)

2. LOCATION SE ¼ SE ¼ Sec 28 T. 19 N/S R. 33 E.
PERMIT/WAIVER No. SW SW 27 (Issued by Water Resources) 08-431-14 Parcel No.
Latitude
Longitude
Subdivision Name:
UTM E 342183 N 4371060 ☒ NAD 27 ☐ NAD 83/WGS 84
County: Churchill

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other...

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Brown Sands		1	15	14
Brown clay		15	19	4
Brown sands		19	40	21
Grey clay		40	43	3
Grey Sands		43	65	23
Grey Clay		65	67	2
Brown sands		67	90	23
Brown clay		90	96	6
Grey Sands		96	110	14
Blk Silt / clays		110	125	15
Grey sands		125	135	10
Grey clay		135	140	5
Brown sands		140	158	18

Date started 10-15, 20 11
Date completed 10-15, 20 11

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1

8. WELL CONSTRUCTION
Depth Drilled 158 Feet Depth Cased 158 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	100	Feet
6 5/8	Inches	100	Feet	158	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	158

Perforations:
Type of perforation ~~.080~~ Machine slot
Size of perforation .080
From 140 feet to 146 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 31' 4" feet below land surface
Artesian flow NO G.P.M. P.S.I
Water temperature Cool °F Quality OK

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Weber Corp (Contractor)
Address P.O. Box 888 (Contractor)
Fallon, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed (By driller performing actual drilling on site or contractor)
Date 10-24-11

(Rev. 06/10)

39.476551 °N NAD27
118.834805 °W Decl Deg

USE ADDITIONAL SHEETS IF NECESSARY