

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 117343  
Permit No. \_\_\_\_\_  
Basin 129

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67910

1. OWNER George Hall  
MAILING ADDRESS PO Box 574 McGill  
NU 89318

ADDRESS AT WELL LOCATION #10 East Creek  
Road Ely NU 89301  
Subdivision Name: \_\_\_\_\_ County: White Pine

2. LOCATION SE 1/4 SW 1/4 Sec 20 T 19 N R 65 E  
PERMIT/WAIVER No. -A 010-710-13  
Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_

Latitude N39°29.559 UTM E  NAD 27  
Longitude W114°41.178 N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Stock  Monitor

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	2	2
Hard Rock		2	130	128
Fractured Rock	X	130	195	65
Hard Rock		195	197	2

This well has 7' of 8" steel casing grouted after top of 6" pvc at surface

9. WELL CONSTRUCTION

Depth Drilled	<u>197</u>	Feet	Depth Cased	<u>197</u>	Feet
---------------	------------	------	-------------	------------	------

HOLE DIAMETER (BIT SIZE)

	From	To	
<u>11</u>	Inches <u>0</u>	Feet <u>197</u>	Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>197</u>

Perforations:

Type of perforation	<u>saw cut</u>			
Size of perforation	<u>1/8" x 3"</u>			
From	<u>100</u>	feet to	<u>197</u>	feet
From		feet to		feet
From		feet to		feet
From		feet to		feet
From		feet to		feet

Annular Seal:  Yes  No

<input type="checkbox"/> Neat Cement	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Concrete Grout	<u>0</u> to <u>100</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack:  Yes  No 100 to 197  Pumped  Poured  
Type: 4 1/2" minus

Bentonite Chips:  Yes  No to  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 7-25-2013, 20  
Date completed: 7-30-2013, 20

7. Water Level  
Static water level: 137 feet below land surface  
Artesian Flow: 0 G.P.M. 0 P.S.I.  
Water Temperature: cold °F  
Quality: Good

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>2</u>	<u>2</u>
<u>NAD 27</u>	<u>39.492 m³/d</u>		
<u>114.6854570</u>			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name: Davis Drilling Contractor  
Address: HC 61 Box 54 Hiko NU 89017 Contractor  
Nevada contractor's license number issued by the State Contractor's Board: 0028966  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1191  
Signed: Mike Davis  
By driller performing actual drilling on-site or contractor  
Date: 7-31-2013

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY