

3/4 wells

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117358
Permit No.
Basin 083

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67199

1. OWNER William Hanson
MAILING ADDRESS 2830 Goldfield Rd
Reno-VCH, NV 89521
ADDRESS AT WELL LOCATION 2830 Goldfield Rd
Reno-VCH, NV 89521
Subdivision Name:
County: Storey

2. LOCATION SW 1/4 NE 1/4 Sec 28 T18 N R21 E
Latitude N39 24 009 UTM E
Longitude W119 37 640 N
PERMIT/WAIVER NO. 003-351-43
Issued by Water Resources Parcel No.

3. WORK PERFORMED
[X] New Well [] Replace [] Recondition
[] Deepen [] Other Geo-Loops
4. PROPOSED USE
[X] Domestic [] Irrigation [] Test
[] Municipal/Industrial [] Monitor [] Stock
5. WELL TYPE
[X] Cable [X] Rotary [] RVC
[X] Air [] Other

LITHOLOGIC LOG table with columns: Material, Water Strata, From, To, Thickness. Rows include Top Soil, Reddish Brown Sandy Clays, Soft Zone, Purple Sandy Clays, etc.

9. WELL CONSTRUCTION
Depth Drilled 301 Feet Depth Cased 301 Feet
HOLE DIAMETER (BIT SIZE)
From To
6 1/8 Inches 0 Feet 301 Feet

CASING SCHEDULE table with columns: Size O.D. (Inches), Weight/Ft. (Pounds), Wall Thickness (Inches), From (Feet), To (Feet). Row: 1" POLY GEO-Loops +5 301

Perforations:
Type of perforation NONE
Size of perforation
From feet to feet

Annular Seal: [X] Yes [] No
[] Neat Cement to [] Pumped [] Poured
[X] Cement Grout 0 to 301 [X] Pumped [] Poured
[] Concrete Grout to [] Pumped [] Poured
[] >30% Bentonite Grout to [] Pumped [] Poured
Gravel Pack: [] Yes [X] No to [] Pumped [] Poured
Type:
Bentonite Chips: [] Yes [X] No to [] Pumped [] Poured
Type:

7. Water Level
Static water level: feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality: not tested
Date started: 1-16, 20 12
Date completed: 1-17, 20 12

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc.
(CONTRACTOR)

8. WELL TEST DATA table with columns: TEST METHOD (Bailer, Pump, Air Lift), Draw Down (Feet Below Static), Time (Hours), G.P.M.

Address 1600 Mt. Rose Hwy
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23095
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor
Date 1-19-12