STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117400
Permit No.
Basin 059

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69896

1. OWNER Carson Tahoe Investments
MAILING ADDRESS 1648 Beverly Dr
NW CC NV 89701

ADDRESS AT WELL LOCATION 400 Ponderosa Point Dr
Subdivision Name: County: Washoe

2. LOCATION NE ¼ SW ¼ Sec 26 T 16 N/S R 19 E
PERMIT/WAIVER No. DOM 13-39 | 055-301-41
Issued by Water Resources Parcel No.

Latitude 39° 13.658
Longitude 119° 49.259
UTM E ☐ NAD 27
N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Dirt		0	8	8
Brown Rock/clay		8	34	26
Brown Rock		34	90	56
Black & White Granet		90	163	73
Green Gritty Clay		163	335	172
White & Black		335	+	
Granet With Brown		+	+	
Red & Green Rock		x	390	55

RECEIVED 2013 AUG -7 PM 2:42 STATE ENGINEERS OFFICE

Date started: 7-16-13, 20
Date completed: 7-22-13, 20

7. Water Level
Static water level: 306 feet below land surface
Artesian Flow: N/A G.P.M. 10 P.S.I.
Water Temperature: cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
375'	10		3
NAD27, 39.227724°N 119.919966°W			

9. WELL CONSTRUCTION
Depth Drilled 390 Feet Depth Cased 390 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	55	Feet
9 7/8	Inches	55	Feet	390	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	10
6 5/8		SDR 21	10	390

Perforations:
Type of perforation Factory Screen
Size of perforation 3/32
From 350 feet to 390 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 58 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 58 to 390 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO INC.
Contractor
Address P.O. Box 1255
Carson City, NV 89702
Contractor

Nevada contractor's license number issued by the State Contractor's Board 46498A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2321

Signed C. Robinson
By driller performing actual drilling on-site or contractor
Date 7-23-13

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(O) 627