

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 117452
 Permit No. _____
 Basin 1b2

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33114

1. OWNER Lyle & Rene Herbert ADDRESS AT WELL LOCATION
 MAILING ADDRESS 6101 Kent St. Pahrump, NV 89048 6101 Kent St. 36D 07.079N 115D 54.171W WGS 84

2. LOCATION S/W 1/4 S/W 1/4 Sec. 15 T 21S N/S R 54E E NYE County
 PERMIT NO. 45-161-11 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown loam and rock		0	52	52
brown caleche		52	74	22
brown caleche and rock		74	84	10
brown loam with rock	x	84	109	25
brown caleche	x	109	114	5
brown clay	x	114	128	14
brown loam with rock	x	128	212	84
brown clay with rock	x	212	240	28

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240+1 Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 240 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>240</u>

Perforations:
 Type perforation sawcut
 Size perforation .188
 From 120 feet to 140 feet
 From 160 feet to 180 feet
 From 200 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 240 feet

DCNR/DWR/SNBO
 RECEIVED
 JUN 10 2013

Date started 5/1/2013, 19____
 Date completed 5/1/2013, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 95 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed Randy Strickland
 By driller performing actual drilling on-site or contractor
 Date 6.4.13

36, 117983
 - 115, 90285