WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 117594
Permit No.
Basin 162

NOTICE OF INTENT NO. 33109

1. OWNER Perry Isaacs
MAILING ADDRESS 2300 E. Virginia Street
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
2300 E. Virginia Street

2. LOCATION S/E 1/4 N/W 1/4 Sec. 1 T 22S N/S R 53E E Nye County
PERMIT NO. (Issued by Water Resources) 41-382-30 (Parcel No.) Calvada (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Loam		0	15	15
See next line		15	45	30
Bronw Loam with Caleche Strings				
Brown Clay		45	80	35
Grey Clay	x	80	120	40
Dark Grey Clay	x	120	410	290

N 36° 03.92 NAD 83
W 115° 58.147

APR 29 2013
SCNR/DWR/SNBO
RECEIVED

Date started 3/25/1913 2013 DSB
Date completed 3/28/1913 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400+1 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	400	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	400

Perforations:
Type perforation sawcut
Size perforation .188
From 100 feet to 120 feet
From 160 feet to 180 feet
From 220 feet to 240 feet
From 280 feet to 300 feet
From 320 feet to 340 feet
From 360 feet to 380 feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 78 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. (Contractor)
Address 5801 S. Homestead (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Kacey Strickland (By driller performing actual drilling on-site or contractor)
Date 4-25-13

36.0653682
115.9682618