corrected

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117604
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please do not leave this form in the entirety for accurate records. (NRS 534.170 and NAC 534.4364)

NOTICE OF INTENT NO. 70130

1. OWNER: Amani Huber
MAILING ADDRESS: P.O. Box 1563
Winnemucca NV. 89446

ADDRESS OF WELL LOCATION: 6370 Staunton Dr.
Winnemucca NV.
Subdivision Name: Sonoma Ranches #1 County: Humboldt

2. LOCATION: SE ¼ NE ¼ Sec 7 T 35 N/S R 36 E/W
Latitude N40° 55.467 Longitude W117° 44.197
UTM E: N: ☐ NAD 27 ☐ NAD 83/WGS 84
PERMIT/WAIVER No. 010-474-20 (Issued by State Engineer) Parcel No.

3. WORKED PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE: ☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☒ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Status	From	To	Thickness
Sand	NO	0	2	2
Clay	NO	2	10	8
Fractured Basalt	NO	10	165	155
Fractured Limestone	NO	165	290	125
Fractured limestone	yes	290	390	100

Date started: 7-11, 20 13
Date completed: 7-18, 20 13

9. WELL CONSTRUCTION
Depth Drilled 390 Feet Depth Cased 370 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 7/8	Inches	0	Feet	50	Feet
8 3/4	Inches	50	Feet	390	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	10
10 7/8	PVC	Sched 40	10	370

PERFORATION
Type of perforation: Slot
Size of perforation: .20
From 310 feet to 370 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

ANNULAR SEAL: ☒ Yes ☐ No

☒ Neat Cement	0 to 20	☐ Pumped	☒ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 370 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 20 to 50 ☐ Pumped ☒ Poured
Type: 3/8" Chip

7. WATER LEVEL
Static water level: 250 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	NA	4

NAD 27
40.924450°N
117.736613°W

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Allied Drilling Inc.
Address (Contractor): 5140 Jungo Rd.
Winnemucca NV 89445
Nevada contractor's license number issued by the State Contractors Board: 76778
Nevada driller's license number issued by the Division of Water Resources, the owner's driller: 1563
Signed: By driller performing actual drilling on-site or contractor
Date: 7-31-13

RECEIVED 2013 SEP 11 AM 10:00 ENGINEERS OFFICE

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-03)

(NSPO 3-08) (O) 627