STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 17612
Permit No.
Basin 179

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68009

1. OWNER (Jody + Kerri Pintar) Jody & Kerri Pintar
MAILING ADDRESS 1417 Mill Street Ely, NV 89301

ADDRESS AT WELL LOCATION 719 E. 308 S. Ely, NV 89301
Subdivision Name: County: White Pine

2. LOCATION SW ¼ SW ¼ Sec 7 T 15 N/S R 64 E
PERMIT/WAIVER No. 012-780-13
Issued by Water Resources Parcel No.

Latitude 39° 10.404 UTM E ☐ NAD 27
Longitude 114° 50.156 N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Gravel, Cobbles		240	300	60
Gravel, Cobbles, Boulders		300	350	50

Deepens well log # 72488

RECEIVED 2012 SEP 10 AM 11:04 STATE ENGINEERS OFFICE

Date started: Sept. 5, 2012
Date completed: Sept. 6, 2012

9. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
5 7/8	Inches	240	Feet	350	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5.5		.250	240	350

Perforations:
Type of perforation Mill
Size of perforation 3/16 x 2 1/2 x 5 rows
From 240 feet to 350 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 138 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1HR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Brothers Drilling, Inc
Contractor
Address PO Box 965
Contractor
Enterprise, UT 84725
Nevada contractor's license number issued by the State Contractor's Board 0068459
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2468
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 9-6-12

(Rev 05 06)
39.173459°N
114.835084°W
NAD27

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627