WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 117649
Permit No.
Basin 030A

NOTICE OF INTENT NO. 65395

1. OWNER Kings River Ranch
MAILING ADDRESS 129 Kings River Rd
Orovada, Nevada 89425

ADDRESS AT WELL LOCATION
29360 Kings River Rd
Orovada NV. 89425

2. LOCATION SE ¼ SW ¼ Sec. 8 T. 44 N/S R. 34 E. Humboldt County
PERMIT NO. (Issued by Water Resources) Parcel No. N 41° 41' 523" W118° 10' 53.6" NAD 83/WGS 84 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
DG Sand / Clay seams		5	40	35
Soft Brown Clay		40	87	47
DG Sand	90	87	100	13
Clay / Seam DG Sand		100	160	60
Course Sand / Clay Seams	160	160	200	40
Course Sand Clay Seams	200	200	240	40

RECEIVED 2012 MAR 15 AM 10:34 STATE ENGINEER'S OFFICE

Date started 1-20-12, 19
Date completed 2-1-12, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	2	1

NAD 27 41.699352° N
118.180569° W

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12	0	50
8	50	240

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		.188	0	240

Perforations:
Type perforation 1/8 x 2 x 8 Rows
Size perforation SAW SLOT
From feet to feet
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kings River Ranch (Contractor)
Address 129 Kings River Rd. (Contractor)
Orovada, NV. 89425
Nevada contractor's license number issued by the State Contractor's Board 73391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1212
Signed Mike McDonald (By driller performing actual drilling on site or contractor)
Date 3-1-12

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627