

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY
Log No. 117700
Permit No. _____
Basin 104

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 67784 ✓

1 OWNER TEXAS ALLIANCE GROUP INC. ADDRESS AT WELL LOCATION 3460 SOUTH CARSON STREET
MAILING ADDRESS 11288 WEST ROAD CARSON CITY, NV 89701
HOUSTON, TEXAS 77065 Subdivision Name: _____ County: Carson City

2 LOCATION SW 1/4 NW 1/4 Sec 29 T 15N N/S R 20 E Latitude 39.13569°N UTM E _____ NAD 27
PERMIT/WAIVER No. 009-111-31 Longitude 119.77022°W N _____ NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3 TYPE OF WELL Domestic Irrigation Test Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? NO
If yes, what is replacement well NOI? _____
Is there an existing well log? NO
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 125 Feet
EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	125

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____
Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations: _____

Existing Perforations:

Type of perforation	Size of perforation	From	feet to	To	feet
FACTORY MILL SLOT	3 X 3/32	From	105	feet to	125
		From		feet to	
		From		feet to	
		From		feet to	
		From		feet to	

Type of perforator used:

From	feet to	feet	Number of perfs per linear foot
From	50	feet to 105	feet 4
From		feet to	feet
From		feet to	feet
From		feet to	feet
From		feet to	feet
From		feet to	feet

5 WATER LEVEL
Static water level 89 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I. _____
Water temperature POOR °F Quality POOR

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From	0	feet to 125	feet NEAT CEMENT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
From		feet to	feet	<input type="checkbox"/>	<input type="checkbox"/>
From		feet to	feet	<input type="checkbox"/>	<input type="checkbox"/>
From		feet to	feet	<input type="checkbox"/>	<input type="checkbox"/>
From		feet to	feet	<input type="checkbox"/>	<input type="checkbox"/>
From		feet to	feet	<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments

RECEIVED
2012 MAY 21 PM 2:14
STATE ENGINEERS OFFICE

Neat Cement Fluid Weight 94/4 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 05/11/2012
Date Completed _____

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. Contractor
Address 20 KIT KAT DRIVE Contractor
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [Signature]
by driller performing actual drilling on site or contractor
Date 05/17/2012

USE ADDITIONAL SHEETS IF NECESSARY

NAD27
39.135781°N 119.769206°W