STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117721
Permit No.
Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67137

1. OWNER GoFer Market
MAILING ADDRESS 2000 Kirman Ave. Reno, NV

ADDRESS AT WELL LOCATION Facility ID: 4-000502 18D
4600 N Virginia Street Reno, NV
Subdivision Name: County: Washoe

2. LOCATION NW ¼ SW ¼ Sec 26 T 20N N/S R 19 E
PERMIT/WAIVER No. 003-091-18
Issued by Water Resources Parcel No.

Latitude 39.57033 Longitude -119.824624
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay with coarse cobbles,				
loose sandy silt		0	20	20
Moist clay		20	35	15
Silty clay, stiff		35	40	5
Clay with cobbles		40	65	25
Boulders and cobbles with clay		65	90	25

Date started: 3-Feb , 20 12
Date completed: 4-Feb , 20 12

RECEIVED 2012 MAR 23 AM 10:24

9. WELL CONSTRUCTION
Depth Drilled 90 Feet Depth Cased 90 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8 1/4	Inches	0	Feet	90	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		Sch 40	0	90

Perforations:
Type of perforation Slot
Size of perforation .010
From 70 feet to 90 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 3 to 63 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 68 to 90 ☐ Pumped ☒ Poured
Type: 2/12 Sand
Bentonite Chips: ☒ Yes ☐ No 63 to 68 ☐ Pumped ☒ Poured
Type: 3/8 Chips

7. Water Level
Static water level: 50 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling, L.P. (Contractor)
Address 3632 Omec Circle (Contractor)
Rancho Cordova, CA 95742
Nevada contractor's license number issued by the State Contractor's Board 0073966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2425
Signed (By driller performing actual drilling on site or contractor)
Date 3/10/2012

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

NAD27 39.570420°N -119.823598°W