STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117733
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68636

1. OWNER LL Reality
MAILING ADDRESS P.O. Box 1344
Fernley, NV 89408

ADDRESS AT WELL LOCATION 4025 Sheckler Rd
Fallon, NV 89406
Subdivision Name: County: Churchill

2. LOCATION NE ¼ NE ¼ Sec 4 T 18N N/S R 28 E
PERMIT/WAIVER No. 006-231-01
Issued by Water Resources Parcel No.

Latitude 39.45945 N
Longitude 118.83854 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	42	42
Brown Clay		42	46	4
Gray Clay		46	51	5
Gray Sand		51	164	113
Fine Brown Sand		164	165	1
Brown Sand	XX	165	180	15

RECEIVED 2012 MAY 14 PM 1:33 STATE ENGINEERS OFFICE

Date started: 30 APR, 20 12
Date completed: 1 May, 20 12

7. Water Level
Static water level: 24 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
replaces unknown log		

9. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	0	19
6.625	4.0	.316	19	180

Perforations:
Type of perforation Saw Cut
Size of perforation 0.125
From 176 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 5 to 15 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 15 to 65 ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 65 to 180 ☐ Pumped ☒ Poured
Type: 3/8" Well Gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2307
Signed (By driller performing actual drilling on site or contractor)
Date 5/9/2012

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

NAD27 39.459233°N, 118.837553°W