

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY
Log No. 117770
Permit No. _____
Basin 105

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 68334 ✓

1 OWNER Carson City Public Works
MAILING ADDRESS 2355 Butti Way
Carson City, NV. 89701

ADDRESS AT WELL LOCATION NW corner of Snyder Ave. and Edmonds
Drive, Carson City, NV.
Subdivision Name: _____ County: Carson City

2 LOCATION SW ¼ SW ¼ Sec 33 T 15N N/S/R 20 E
PERMIT/WAIVER No. _____
Issued by Water Resources Parcel No.

Latitude 39 06.856N UTM E NAD 27
Longitude 119 44.773W N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? _____
If yes, what is replacement well NOI? _____

Is there an existing well log? yes
If yes, what is NDWR well log #? 23483

4 EXISTING WELL CONSTRUCTION
Depth Drilled 235 Feet Depth Cased 235 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>		<u>.250</u>	<u>+1</u>	<u>235</u>

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used: _____ Mills Knife
From 70 feet to 48 feet Number of perfs per linear foot 4
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

Existing Perforations:

Type of perforation	Size of perforation	From	To
<u>double row slotted</u>	<u>3/32" X 3"</u>	<u>70</u> feet to	<u>235</u> feet

5 WATER LEVEL
Static water level 38.76 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

6 WELL PLUGGING MATERIALS
Material Used
From 0 feet to 235 feet neat cement Pumped Poured
From _____ feet to _____ feet Pumped Poured

6 Additional Notes or Comments

Removed 168' of 4" drop pipe with 40 hp pump from well.
Measured water level at 38.76' and depth of well at 234'.
Installed 8" Mill s Knife and perforated casing from 70' back to 48' where surface seal was in place. Installed 231' of 2" tremme pipe. Following day we pumped in 5 cubic yards of neat cement. Measured top of cement at 7' below grade following morning. Mixed concrete and filled well to surface.

Neat Cement Fluid Weight 14.3 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 7/2/2012
Date Completed 7/3/2012

plugs well log # 23483

RECEIVED
JUL 23 PM 12:02
STATE ENGINEERS OFFICE

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Carson Pump, LLC Contractor
Address P.O. Box 20159 Contractor
Carson City, NV. 89721
Nevada contractor's license number _____
issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2265
Signed [Signature]
Date 7/13/2012

USE ADDITIONAL SHEETS IF NECESSARY

NAD 83 39.114357°N, 119.745204°W