STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117790
Permit No.
Basin 153

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68633

1. OWNER Giovani Minoletti
MAILING ADDRESS P.O. box 296
Eureka, NV 89316

ADDRESS AT WELL LOCATION 580 Minoletti Rd.
Eureka, NV 89316
Subdivision Name: County: Eureka

2. LOCATION SE ¼ NW ¼ Sec 32 T 20N N/S R 53 E
PERMIT/WAIVER No. 007-340-29
Issued by Water Resources Parcel No.

Latitude 39.55313 N
Longitude -116.02844 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	8	8
Clay		8	96	88
Cement Gravel		96	128	32
Gravel		128	155	27
Cement Gravel		155	201	46
Gravel w/s Sand		201	207	6
Gravel	XX	207	216	9

RECEIVED
2012 MAY -7 PM 1:21
STATE ENGINEERS OFFICE

Date started: 5-Apr , 20 12
Date completed: 6-Apr , 20 12

9. WELL CONSTRUCTION
Depth Drilled 216 Feet Depth Cased 216 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	216	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	17.02	.250	196	0
6.625	12.92	.188	216	196

Perforations:
Type of perforation Mill Cut
Size of perforation 0.1875
From 196 feet to 216 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 5 to 15 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 15 to 60 ☒ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 196 to 216 ☐ Pumped ☒ Poured
Type: 60 3/8" Well Gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 112 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2307
Signed (By driller performing actual drilling on site or contractor)
Date 4/20/2012

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

NAD27 39.553201°N, 116.027547°W