STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117801
Permit No.
Basin 070

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68263 ✓

1. OWNER Bodily Living Trust
MAILING ADDRESS PO Box 488 Winnemucca, NV

ADDRESS AT WELL LOCATION East Second/Bodily
Winnemucca, NV 5055 E. Second St.
Subdivision Name: County: Humboldt

2. LOCATION NW¼SW¼ Sec16T36N/ R38E
PERMIT/WAIVER NO. N/A (Issued by Water Resources) 010-272-01 (Parcel. No.)

Latitude N40°59.622 UTM E ☐ NAD 27
Longitude W117°42.905 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Course gravel		2	40	38
Clay		40	50	10
Sand/Gravel		50	70	20
Cobbles		70	80	10
course gravel	X	80	115	35
Clay		115	120	5
Reference Well Log	31957			

Date started: July 30, 2012
Date completed: July 31, 2012

7. Water Level
Static water level: 30 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		3

40.993798°N NAD 27
117.714121°W

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	+1	20
6.625 PVC	4.06	.316	20	120

Perforations:
Type of perforation Factory Cut
Size of perforation 050
From 80 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 120 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed
By driller performing actual drilling on site or contractor
Date August 23, 2012

RECEIVED 2012 AUG 30 AM 10:20 STATE ENGINEER'S OFFICE