STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117840
Permit No.
Basin 089

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69133

1. OWNER George Gillemot
MAILING ADDRESS 4814 Old US 395
Washoe Valley, NV 89704

ADDRESS AT WELL LOCATION 4935 Old US 395
Washoe Valley, NV 89704
Subdivision Name: County: Washoe

2. LOCATION NE¼NW¼ Sec10T16N/ R19E
Latitude 39.26973 UTM E ☐ NAD 27
Longitude -119.84005 N ☒ NAD 83/WGS 84

PERMIT/WAIVER NO. 055-051-10
Issued by Water Resources Parcel. No.

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we perforated the well from 215'-380' and 160'-210'. We then filled the well with neat cement from 485' to 238'. This was a recondition of the well and we abandoned the well from 238'-485' where it was already abandoned from from 485'-678'. Well is now perforated from 160' to 238' and abandoned from 238'-678'.				
Washoe Co. Permit WL#120024				

Date started: 8-15, 20 12
Date completed: 8-15, 20 12

7. Water Level
Static water level: 50 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: cold °F
Quality: Not Tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	75+		2 Hrs.
Pump	75	35	2 Hrs

9. WELL CONSTRUCTION
Depth Drilled 238 Feet Depth Cased 238 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	238

Perforations:
Type of perforation Air Perforator
Size of perforation Puncture
From 160 feet to 210 feet
From 215 feet to ~~238~~ 380 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☒ Neat Cement 238 to 485 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (CONTRACTOR)
Address 1600 Mt. Rose Hwy (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor
Date 8-16-'12

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

NAD27 39.269821°N, 119.839031°W