

**STATE OF NEVADA**  
**DIVISION OF WATER RESOURCES**  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 117899  
 Permit No. \_\_\_\_\_  
 Basin 069

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68949 ✓

1. OWNER **Scott & Stephanie Huesboe**  
 MAILING ADDRESS **PO Box 72 - Paradise Valley, NV**

ADDRESS AT WELL LOCATION **Family Trust well**  
 Subdivision Name: \_\_\_\_\_ County: **Humboldt**

2. LOCATION **NW 1/4 NW 1/4 Sec11/12T41N/ R39E**  
 PERMIT/WAIVER NO. **N/A** **004-475-03**  
Issued by Water Resources Parcel No.

Latitude **41°27.283** UTM E  NAD 27  
 Longitude **117°32.171** N  NAD 83/WGS 84

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	3	3
Course/fine sand		3	40	37
Cobbles/gravel		40	55	15
Clay		55	80	25
Sand/fine gravel	X	80	115	35
Clay		115	130	15
Sand/fine gravel	X	130	160	30
Clay		160	170	10

RECEIVED  
 2012 MAY 11 AM 10:49  
 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION

Depth Drilled **170** Feet Depth Cased **170** Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
**12** Inches **0** Feet **170** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>10</b>	<b>188</b>	<b>+1</b>	<b>10</b>
<b>6.625</b>	<b>4.06</b>	<b>.316</b>	<b>10</b>	<b>170</b>

Perforations:  
 Type of perforation **Factory Cut Slots**  
 Size of perforation **050**  
 From **135** feet to **165** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement **0** to **50**  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Gravel Pack:  Yes  No **55** to **170**  Pumped  Poured  
 Type: \_\_\_\_\_  
 Bentonite Chips:  Yes  No **50** to **55**  Pumped  Poured  
 Type: \_\_\_\_\_

Date started: **April 19, 2012**  
 Date completed: **April 26, 2012**

7. Water Level  
 Static water level: **47** feet below land surface  
 Artesian Flow: **N/A** G.P.M. **N/A** P.S.I.  
 Water Temperature: **Cool** °F  
 Quality: **Good**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Fred Anderson Drilling, Inc.**  
(CONTRACTOR)

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump Draw Down	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Time (Hours)		
<b>30</b>	<b>5</b>		

Address **10760 S. Grass Valley Road**  
(CONTRACTOR)

**Winnemucca, NV 89445**  
 Nevada contractor's license number issued by the State Contractor's Board **021467**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2083**

Signed *Fred Anderson Drilling Inc.*  
 By driller performing actual drilling on site or contractor  
 Date **May 8, 2012**

**NAD27 41.454820°N, 117.535221°W**