STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117968
Permit No.
Basin 153

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69265

1. OWNER Dwayne ~~Knutson~~ + Linda Knudsen
MAILING ADDRESS P.O Box 875
Eureka, NV 89316

ADDRESS AT WELL LOCATION 1290 Gitla Ave
Fallon, NV 89316
Subdivision Name: County: Eureka

2. LOCATION NE ¼ SE ¼ Sec 4 T 21N N/S R 54 E
PERMIT/WAIVER No. 007-450-10
Issued by Water Resources Parcel No.

Latitude 39.71620 N
Longitude 115.89092 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ ~~New Well~~ ☒ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay Sand		0	10	10
Sand Gravel		10	26	16
Clay Gravel		26	34	8
Gravel Clay		34	96	62
Gravel Rock		96	132	36
Gravel Clay		132	161	29
Gravel Rock		161	187	26
Gravel Clay		187	205	18
Gravel Rock	XX	205	280	75

2012 OCT 3 AM 10:30
STATE ENGINEER'S OFFICE

* Replaces original well log # 106975 which was plugged under NOI # 69268

Date started: 6-Sep, 20 12
Date completed: 14-Sep, 20 12

7. Water Level
Static water level: 150 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
39.716273°N		NAD27
115.890031°W		

9. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	280	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	0	180

Perforations:
Type of perforation Mill Cut
Size of perforation 0.1875
From 240 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 55 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No to ☐ Pumped ☒ Poured
Type: 3/8" Well gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2307
Signed (By driller performing actual drilling on site or contractor)
Date 9/19/2012

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY