STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118000
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68905

1. OWNER BE B ANDRAE
MAILING ADDRESS 161 KITTRIDGE CANYON #5
ELKO, NV 89801

ADDRESS AT WELL LOCATION 3735 STATICE ST
Subdivision Name: MVR #5 County: ELKO

2. LOCATION SE ¼ SW ¼ Sec 35 T 35N N/S R 55 E
PERMIT/WAIVER No. 037-062-006
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0605299 [X] NAD 27
N 4524815 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL	X	320	385	65
TAN CLAY		385	390	5
EXISTING WELL LOG #75740				

RECEIVED 2012 JUL 20 AM 10:11 STATE ENGINEERS OFFICE

Date started: 30-May, 20 12
Date completed: 1-Jun, 20 12

9. WELL CONSTRUCTION
Depth Drilled 390 Feet Depth Cased 383 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	320	Feet	390	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5.5	20.8	.375	283	383

Perforations:
Type of perforation PLASMA CUT
Size of perforation 3/16" X 4", 6 ROWS
From 323 feet to 383 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [ ] Yes [X] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 242 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 62 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
130 PSI @			
825 CFM	20		5 HOURS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1166
Signed (By driller performing actual drilling on site or contractor)
Date 6/1/2012

(Rev. 05-06) USE ADDITIONAL SHEETS IF NECESSARY

40.869543 °N
115.750462 °W
NAD27