

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 118003
 Permit No. _____
 Basin φ71

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68277

1. OWNER **Todd & Teresa Ricketts** ADDRESS AT WELL LOCATION **7330 Larkspur Lane**
 MAILING ADDRESS **7330 Larkspur Winnemucca, NV** **Winnemucca, NV 89445**
 Subdivision Name: _____ County: **Humboldt**

2. LOCATION **NW¼SE¼ Sec13T36N/ R37E** Latitude **40°54.432** UTM E _____ NAD 27
 PERMIT/WAIVER NO. **N/A** Parcel No. **013-581-13** Longitude **W117°45.813** N _____ NAD 83/WGS 84
Issued by Water Resources

3. WORK PERFORMED New Well Replace Recondition Deepen Other _____
 4. PROPOSED USE Domestic Irrigation Test Monitor Stock Municipal/Industrial Air Other _____
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand/gravel		140	160	20
cobbles/gravel		160	200	40
Course gravel/sand	X	200	240	40
* ORIGINAL LOG BEING DEEPEMED - UNKNOWN				
RECEIVED 2012 OCT 29 AM 11:00 STATE ENGINEERS OFFICE				

9. WELL CONSTRUCTION
 Depth Drilled **240** Feet Depth Cased **240** Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
6 1/4 Inches **140** Feet **240** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	8	1.88	140	240

Perforations:
 Type of perforation **Factory Cut**
 Size of perforation **3/32 X 4**
 From **200** feet to **240** feet
 From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement Exist to _____ Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured
 Gravel Pack: Yes No _____ to _____ Pumped Poured
 Type: **Natural**
 Bentonite Chips: Yes No _____ to _____ Pumped Poured
 Type: _____

Date started: **October 15, 2012**
 Date completed: **October 15, 2012**

7. Water Level
 Static water level: **132** feet below land surface
 Artesian Flow: **N/A** G.P.M. **N/A** P.S.I.
 Water Temperature: **Cool** °F
 Quality: **Good**

8. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
20		3	
40	907296 -N	NAD27	
117	762587 -W		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Fred Anderson Drilling, Inc.** (CONTRACTOR)
 Address **10760 S. Grass Valley Road** (CONTRACTOR)
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board **021467**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2083**
 Signed *[Signature]*
 By driller performing actual drilling on site or contractor
 Date **October 25, 2012**