STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118005
Permit No.
Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68251

1. OWNER Hank & Jody Brackenbury
MAILING ADDRESS PO Box 75 - Yerington NV

ADDRESS AT WELL LOCATION 3915 Celeste
Winnemucca NV
Subdivision Name: County: Humboldt

2. LOCATION NW¼NW¼ Sec24T35N/ R37E
PERMIT/WAIVER NO. N/A (Issued by Water Resources) 014-111-19 (Parcel. No.)

Latitude N40°53836 UTM E ☐ NAD 27
Longitude W117°46459 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand/gravel	X	140	160	20
Clay		160	165	5
Sand/ course gravel	X	165	195	30
Clay		195	210	15
Gravel & Sand	X	210	240	30

RECEIVED 2012 JUN -7 AM 10:56 STATE ENGINEERS OFFICE

40.897363°N NAD 27
117.773353°W

* Original well log being deepened - UNKNOWN

Date started: May 21, 20 12
Date completed: May 22, 20 12

7. Water Level
Static water level: 100 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		4

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	140 Feet	240 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10	188	140	240

Perforations:
Type of perforation Factory Cut Slots
Size of perforation 3/32 x 4
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No

	Existing	to		
☐ Neat Cement			☐ Pumped	☐ Poured
☐ Cement Grout			☐ Pumped	☐ Poured
☐ Concrete Grout			☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout			☐ Pumped	☐ Poured
Gravel Pack: ☐ Yes ☐ No			☐ Pumped	☐ Poured
Type:				
Bentonite Chips: ☐ Yes ☐ No			☐ Pumped	☐ Poured
Type:				

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling, Inc
By driller performing actual drilling on site or contractor
Date June 5, 2012