STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 118006
Permit No.
Basin 071

NOTICE OF INTENT NO. 68266

1. OWNER Jane Schommer
MAILING ADDRESS PO Box 1711 Winnemucca, NV

ADDRESS AT WELL LOCATION 6380 Mills Road
Winnemucca, NV 89446
Subdivision Name: County: Humboldt

2. LOCATION SW¼SE¼ Sec12T35N/ R37E
PERMIT/WAIVER NO. N/A (Issued by Water Resources) 013-512-09 (Parcel. No.)

Latitude 40°55.044 UTM E ☐ NAD 27
Longitude 117°45.701 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		120	130	10
Cobbles & Gravel		130	165	35
Rock		165	170	5
Cobbles & Gravel		170	195	25
Course Gravel	X	195	220	25
* Deepens well log #		93648		

RECEIVED 2012 OCT 17 AM 10: 3 STATE ENGINEER'S OFFICE

Date started: October 4, 20 12
Date completed: October 5, 20 12

7. Water Level
Static water level: 112 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		4
40.	917496°N	NAD27
117.	760720°W	

9. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7 3/4 Inches	120 Feet	220 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	1.88	120	220

Perforations:
Type of perforation Factory Cut
Size of perforation 3/32 X 4
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement Exist to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed By driller performing actual drilling on site or contractor
Date October 10, 2012

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com