STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118015
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69162

1. OWNER Wallace Realty (Ryan + Stacy Greck)
MAILING ADDRESS 525 W Williams Ave.
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4666 Conrad Place
Fallon, NV 89406
Subdivision Name: County: Churchill

2. LOCATION SE ¼ SW ¼ Sec 4 T 18N N/S R 28 E
PERMIT/WAIVER No. 006-231-35
Issued by Water Resources Parcel No.

Latitude 39.44889 N
Longitude -118.84992 W
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	28	28
Brown Clay		28	46	18
Gray Sand		46	52	6
Gray Clay		52	64	12
Black Sand		64	110	46
Black Clay		110	136	26
Gray Sand		136	149	13
Gray Clay		149	152	3
Brown Sand	XX	152	160	8

Date started: 26-Jun, 20 12
Date completed: 27-Jun, 20 12

RECEIVED 2012 JUL 24 AM 11:2 WATER ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6	12.92	.188	20	160

Perforations:
Type of perforation Saw Cut
Size of perforation
From 155 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 5 to 105 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 105 to 160 ☐ Pumped ☒ Poured
Type: 3/8 Gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 14 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, *the on-site driller* 2307
Signed (By driller performing actual drilling on site or contractor)
Date 7/12/2012

(Rev. 05-06) USE ADDITIONAL SHEETS IF NECESSARY

39.448973°N
118.848933°W
NAD27