

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 118048
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68644

1 OWNER Neil & Amy Zimney (Zimney)
MAILING ADDRESS 4655 Tarzyn Rd.
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4655 Tarzyn Rd.
Fallon, NV 89406
Subdivision Name: County: Churchill

2 LOCATION SW 1/4 NE 1/4 Sec 5 T 19N N/S R 29 E
PERMIT/WAIVER No. 007-351-30
Issued by Water Resources Parcel No.

Latitude 39.54231 N UTM E NAD 27
Longitude -118.75005 W N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? Yes
If yes, what is replacement well NOI? 68643
Is there an existing well log? no
If yes, what is NDWR well log #?

4 EXISTING WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why:

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	33.4	.250	0	20

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:

Type of perforation	Unknown
From

Additional Perforations:

Type of perforator used:	Mill Knife
From 0 feet to 20 feet	Number of perfs per linear foot 8
From	Number of perfs per linear foot
From	Number of perfs per linear foot
From	Number of perfs per linear foot
From	Number of perfs per linear foot
From	Number of perfs per linear foot

5 WATER LEVEL
Static water level 13 feet below land surface
Artesian flow

8 WELL PLUGGING MATERIALS

6 Additional Notes or Comments

Material Used	
From 0 feet to 20 feet	Neat Cement <input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Poured
From	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
From	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
From	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
From	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
From	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured

Neat Cement Fluid Weight 15.6 lbs/gal
Bentonite Grout % bentonite
Date Started 5/31/2012
Date Completed 5/31/2012

RECEIVED
2012 JUL 24 PM 11:27
STATE ENGINEERS OFFICE

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2307
Signed [Signature] By driller performing actual drilling on site of contractor
Date 5/31/2012

39.542393 ON
118.749095 OW NAD27

USE ADDITIONAL SHEETS IF NECESSARY

Rev 05-06