STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118073
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35949

1. OWNER Public ROW
MAILING ADDRESS 500 South Grand Central Pkwy, Las Vegas, NV

ADDRESS AT WELL LOCATION Public ROW on Vegas Dr west of Silver Lake Dr
Subdivision Name: County: Clark

2. LOCATION NW ¼ NE ¼ Sec 30 T 20S N/S R 61 E
PERMIT/WAIVER No. DW-1328 (Issued by Water Resources) 13930599001 Parcel No.

Latitude N 267704100.26
Longitude E 769873.4137
UTM E
N
[X] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DW # 27				

DCNR/DWR/SNBC RECEIVED AUG 19 2013

Date started: 19-Apr, 20 13
Date completed: 19-Apr, 20 13

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	3/8	0	30

Perforations:
Type of perforation machine slot
Size of perforation 0.032
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [X] Yes [ ] No 12 to 20 [ ] Pumped [X] Poured
Type: 3/8 Pea Gravel
Bentonite Chips: [X] Yes [ ] No 10 to 12 [ ] Pumped [X] Poured
Type: 3/8's

7. Water Level
Static water level: 16 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Viking Drillers Inc (Contractor)
Address 5950 Granite Lake Dr. (Contractor)
Granite Bay, CA 95746
Nevada contractor's license number issued by the *State Contractor's Board* 0034680
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* DW-2361
Signed (By driller performing actual drilling on site or contractor)
Date 7/28/2013

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36° 11' 18.11" N 36.1883638 NAD27
115° 11' 42.33" W -115.1950916