STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118074
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 35988

1. OWNER Public ROW
MAILING ADDRESS 500 South Grand Central Pkwy, Las Vegas, NV

ADDRESS AT WELL LOCATION Public ROW on Vegas Dr west of Silver Lake Dr
Subdivision Name: County: Clark

2. LOCATION NE ¼ NE ¼ Sec 30 T 20S N/S R 61 E
PERMIT/WAIVER No. DW-1328 (Issued by Water Resources) 13930599002 Parcel No.

Latitude N 26770436.82
Longitude E 771445.5317
UTM E
N
[X] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| DW # 8 | | | | |
| | | | | ##### |

DCNR/DWR/SNBO RECEIVED AUG 19 2013

Date started: 11-Apr, 20 13
Date completed: 11-Apr, 20 13

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 24 | Inches | 0 | Feet | 30 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | 6 | 3/8 | 0 | 30 |
| | | | | |
| | | | | |

Perforations:
Type of perforation machine slot
Size of perforation 0.032
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 12 to 20 [ ] Pumped [X] Poured
Type: 3/8 Pea Gravel
Bentonite Chips: [X] Yes [ ] No 10 to 12 [ ] Pumped [X] Poured
Type: 3/8's

7. Water Level
Static water level: 16 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Viking Drillers Inc (Contractor)
Address 5950 Granite Lake Dr. (Contractor)
Granite Bay, CA 95746
Nevada contractor's license number issued by the *State Contractor's Board* 0034680
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* DW-2361
Signed (By driller performing actual drilling on site or contractor)
Date 7/28/2013

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36° 11' 18.38" N
115° 11' 24.90" W

36.188438
-115.19025
NAD27

THIS BORING LOG IS FOR VIKING'S INTERNAL PURPOSES ONLY. IT DOES NOT REPRESENT INFORMATION PROVIDED BY A SOILS ENGINEER.

| LOG FOR BORING NO. 67(8) | | JOB NAME: CONTI CON | | | |
|---|---|---|---|---|---|
| DATE STARTED 4-11-13 | DATE COMPLETED | LOGGED BY Ed | DRILLED BY Ed | TYPE OF DRILL RIG 300 | JOB NO. 6119 |
| DEPTH OF HOLE 30' | DIAMETER OF HOLE 24" | CASING 8" | PERFORATIONS 20' | SAMPLING METHOD | ELEVATION |

LOCATION

See First Page

DRILLERS NOTES:

10' spacers used

| DEPTH | SAMPLES | GRAPHIC | DESCRIPTION | |
|---|---|---|---|---|
| 0' | | | Road Base, Silt & Rock | |
| | | | Rock | 24" Rock Auger |
| | | | silty clay | |
| 10' | | | white clay | |
| | | | clean chi | 24" Rock Auger |
| | | | silty clay | |
| | | | wet silty clay | |
| 20' | | | clean chi | |
| | | | Red silty clay | |
| 30' | | | | |
| 40' | | | | |
| 50' | | | | |
| 60' | | | | |
| 70' | | | | |
| 80' | | | | |
| 90' | | | | |
| 100' | | | | |

DCNR/DWR/SNBO
RECEIVED
AUG 19 2013

REVIEWED
By Scott Philliber at 11:12 am, Apr 22, 2013

APR 12 2013