STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118124
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69617

1. OWNER JOHN KELLEY
MAILING ADDRESS 780 PINTO CR.
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 780 PINTO CR
GARDNERVILLE, NV 89410
Subdivision Name: County: Douglas

2. LOCATION NE ¼ NW ¼ Sec 24 T 12N N/S R 20 E
PERMIT/WAIVER No. 1220-24-101-004
Issued by Water Resources Parcel No.

Latitude 38.895141*N
Longitude 119.689030*W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 8 5/8		0	120	120
COURSE OBSIDIAN SANDS		120	165	45
COURSE GRAVELS	XX	165	220	55

Date started: 18-Oct, 20 12
Date completed: 22-Oct, 20 12

9. WELL CONSTRUCTION
Depth Drilled 220 ~~100~~ Feet Depth Cased 220 ~~100~~ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 5/8	Inches	120	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.26	.216	100	220
SDR 21				

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation .032
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 90 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	60	3 HRS

NAD27 38.8952339N 119.688023W

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CATITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE
Contractor
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed Michael Hack
By driller performing actual drilling on site or contractor
Date 10/28/2012

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY