STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118158
Permit No.
Basin 179

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69378

1. OWNER Robinson Nevada mining company
MAILING ADDRESS 4232w white pine county rd 44 Ruth nv 89319

ADDRESS AT WELL LOCATION Robinson mine
Subdivision Name: County: White Pine

2. LOCATION NW ¼ Ne ¼ Sec 15 T 16n N/S R 62 E
PERMIT/WAIVER No. 1198 (Issued by Water Resources) Parcel No.

Latitude 39.258096°N Longitude 114.977249°W
UTM E 674527.4 N 4347159.9 ■ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ■ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ■ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ■ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black rock with cly		0	475	475
Grey rock with clay		475	1000	625
Black rock with clay		1000	1250	250
Hole #pz12-17				
PH-A				

RECEIVED 2012 DEC 12 AM 10:53 STATE ENGINEER'S OFFICE

Date started: 11/02, 20 12
Date completed: 11/29, 20 12

9. WELL CONSTRUCTION
Depth Drilled 1250 Feet Depth Cased 1248 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12.75 Inches	0 Feet	20 Feet
6.75 Inches	20 Feet	1250 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"		156 wall	+2	20
2.375"		Sch40	+2	1248

Perforations:
Type of perforation Mill slot
Size of perforation .020
From 548 feet to 1248 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 50 ■ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout 543 to 50 ■ Pumped ☐ Poured
Gravel Pack: ■ Yes ☐ No 546 to 1254 ☐ Pumped ■ Poured
Type: 1/4
Bentonite Chips: ■ Yes ☐ No 543 to 546 ■ Pumped ■ Poured
Type: Coated pellets 3/8"

7. Water Level
Static water level: 676.4 feet below land surface
Artesian Flow: None G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
9	N/a	1 hour

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Nevada (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0073086
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1942
Signed William Riley (By driller performing actual drilling on site or contractor)
Date 12/5/12

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY