

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 118159  
Permit No. \_\_\_\_\_  
Basin 207

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69388

1. OWNER **Robinson Nevada mining company**  
MAILING ADDRESS 4232w white pine county rd 44 Ruth nv 89319

ADDRESS AT WELL LOCATION **Robinson mine**  
Subdivision Name: \_\_\_\_\_ County: White Pine

2. LOCATION NE 1/4 Sec 25 T 16n N/S R 61 E  
PERMIT/WAIVER No. Nev0092105  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude 39.22275 UTM E  NAD 27  
Longitude 115.04946 N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Altkium / sand		0	805	805
Hole# wcc-g5				
<u>WCC-G5</u>				

9. WELL CONSTRUCTION

Depth Drilled 805 Feet Depth Cased 798 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>24</u>	<u>0</u>	<u>20</u>
<u>13</u>	<u>20</u>	<u>690</u>
<u>12.25</u>	<u>690</u>	<u>805</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14"</u>		<u>1/4" wall</u>	<u>+3</u>	<u>20</u>
<u>4.5</u>		<u>Sch80 steel</u>	<u>+2</u>	<u>798</u>

RECEIVED  
2012 DEC 12 AM 10:53  
STATE ENGINEERS OFFICE

Perforations:

Type of perforation Vertical slot  
Size of perforation 1/8"

From 438 feet to 798 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement 0 to 50  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout 50 to 433  Pumped  Poured

Gravel Pack:  Yes  No 436 to 805  Pumped  Poured  
Type: 1/4"

Bentonite Chips:  Yes  No 433 to 436  Pumped  Poured  
Type: 3/8" coated pellets

Date started: 11/26 20 12  
Date completed: 12/5 20 12

7. Water Level  
Static water level: 465 feet below land surface  
Artesian Flow: None G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>150</u>	<u>N/a</u>	<u>1hr</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Boart Longyear Nevada  
Contractor

Address PO Box 2748  
Contractor

Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0073086

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1942

Signed William Ritey  
By driller performing actual drilling on site or contractor

Date 12/7/12

(Rev. 05-06) NAD27 39.222811°N, 115.048604°W USE ADDITIONAL SHEETS IF NECESSARY