STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118165
Permit No.
Basin 106

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69822

1. OWNER BALDO JORCI
MAILING ADDRESS 1927 DAYTON STREET
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 1927 DAYTON STREET
GARDNERVILLE, NV 89410
Subdivision Name: TOPAZ LAKE County: Douglas

2. LOCATION NW ¼ SE ¼ Sec 29 T 10N N/S R 22 E
PERMIT/WAIVER No. 1022-29-310-014
Issued by Water Resources Parcel No.

Latitude 38.69894*N
Longitude 119.54536*W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 8 5/8 WELL		0	175	175
OBSIDIAN SANDS AND GRAVELS		175	210	35
BROWN CLAY		210	245	35
FRACTURED OBSIDIAN SANDS AND GRAVEL		245	280	35

Date started: 06-Nov , 20 12
Date completed: 08-Nov , 20 12

9. WELL CONSTRUCTION
Depth Drilled 105 Feet Depth Cased 105 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	175	Feet	280	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.26	.216	160	280
SDR 21				

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation .032
From 260 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 120 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	62	3 HRS

NAD27 39.699050°N
119.544358°W

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE
Contractor
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed
by driller performing actual drilling on site or contractor
Date 11/12/2012

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY