STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 118173
Permit No.
Basin 178A

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1 OWNER GRANITE CONSTRUCTION
MAILING ADDRESS 1900 GLENDALE AVE
SPARKS, NV 89431

NOTICE OF INTENT NO. 69936 ✓
ADDRESS AT WELL LOCATION ELKO COUNTY MILEPOST 33 NEAR BLM ROAD 1528 ON US 93
Subdivision Name: County: Elko

2 LOCATION ~~SE¼~~ SW¼SE ¼ Sec 36 T 31N N/S R 62 E
PERMIT/WAIVER No. C-171 N/A 36
Issued by Water Resources Parcel No.

Latitude 40° 31' 05" N
Longitude 114° 55' 55" W
UTM E N
☒ NAD 27 ☐ NAD 83/WGS 84

3 TYPE OF WELL
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

Is this well being plugged because a replacement well was drilled? NO
If yes, what is replacement well NOI?

Is there an existing well log? YES
If yes, what is NDWR well log #? 6829

4 EXISTING WELL CONSTRUCTION
Depth Drilled 285' Feet Depth Cased 280' Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"		.250"	0'	280'

Existing Perforations:
Type of perforation MILL SLOT
Size of perforation 1/8" X 6"

From	feet to	feet
135'	280'	

5 WATER LEVEL
Static water level 130' feet below land surface
Artesian flow NO G.P.M. 0 P.S.I
Water temperature COOL °F Quality

6 Additional Notes or Comments

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? ☒ yes ☐ no
If well was not cleaned out to total depth, please explain why:

Was the well contaminated? ☐ yes ☒ no
Was the casing pulled? ☐ yes ☒ no
Was the casing over drilled? ☐ yes ☒ no
If casing was left in place, please show where additional perforations were made:

Additional Perforations:
Type of perforater used: HOLT AIR PERFORATOR

From	feet to	feet	Number of perfs per linear foot
0'	135'		6 Rows

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used		
0'	50'		NEAT CEMENT	☒ Pumped	☐ Poured
50'	280'		BENTONITE GROUT	☒ Pumped	☐ Poured
				☐ Pumped	☐ Poured
				☐ Pumped	☐ Poured
				☐ Pumped	☐ Poured
				☐ Pumped	☐ Poured

Neat Cement Fluid Weight 15 LBS lbs/gal
Bentonite Grout 30% % bentonite
Date Started 11/12/2012
Date Completed 11/12/2012

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources - West, Inc. (Contractor)
Address 4975 W. Winnemucca Blvd. (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 56797
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* #1713
Signed Michelle Strother (By driller performing actual drilling on site or contractor)
Date 11/29/2012

NAD27 40.581128°N
114.931075°W

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY