STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118179
Permit No.
Basin 069

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66130

1. OWNER Harvey Schwartz
MAILING ADDRESS 10 Davis Creek NV 89704

ADDRESS AT WELL LOCATION 10 Davis Creek Cir.
Subdivision Name:
County: Washoe

2. LOCATION NE ¼ NE ¼ Sec 34 T 17 N/S R 19 E
PERMIT/WAIVER No. 046-041-15
Issued by Water Resources
Parcel No.

Latitude 39.30149
Longitude 119.83121
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Cobbles		4	105	101
large Gritty Sand		105	111	6
DG		111	128	117
Black & White Grannit		117	130	23
DG with Black & White Grannit		130	188	58
Brown DG		188	194	6
Brown Clay		194	207	13
Gritty Sand		207	215	8
Grannit		215	266	51
DG		266	240	34
Black & White Grannit with Small Multi Colored Gravel		290	307	17
Multi Colored Small Gravel		307	398	91
larg brown Sand		398	405	7

RECEIVED 2013 JAN STATE ENGINEER'S OFFICE

Date started: 11-24-12, 20
Date completed: 11-27-12, 20

7. Water Level
Static water level: 110 feet below land surface
Artesian Flow: NO G.P.M. 25+ P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
395	25+	NA	2
210	25+	NA	1.5

9. WELL CONSTRUCTION
Depth Drilled 405 Feet Depth Cased 405 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	249	Feet
6	Inches	249	Feet	405	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	+2	249'
5"		.188	240	405'

Perforations:
Type of perforation Torch cut & Factory
Size of perforation 3" x 5/32
From TC ~~244~~ 244 feet to 249 feet
From TC 385 feet to 405 feet
From F 345 feet to 365 feet
From F 385 feet to 405 feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 106 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 106 to 249 ☐ Pumped ☐ Poured
Type: 3/8 to 5/8 Round Rock
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO INC.
Contractor
Address P.O. Box 1255
Carson City, NV 89702
Contractor

Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2134

Signed [signature]
By driller performing actual drilling on site or contractor
Date 12-12-12

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-08)