STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 11924
Permit No.
Basin No. 154

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67462

1. OWNER/CLIENT NAME Goicoechea Ranches
MAILING ADDRESS P.O. Box 97
Eureka, NV 89316

DETAILED ADDRESS AT WELL LOCATION 12500 N SR 892
County Eureka

2. PLS LOCATION SW ¼ SW ¼ 14 Sec 20N N/S 55 E
PERMIT/WAIVER NO. 009-010-03
Latitude W115*753651 UTM E ☐ NAD 27
Longitude N39*59.728 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☒ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost	Water	From	To	Thickness
sand/gravel		110	0	120	120

NAD27
39.59735°N
115.755627°W

Date started: 22-Aug, 20 13
23-Aug, 20 13

9. WELL CONSTRUCTION
Depth Drilled: 120 Feet Depth Cased: 120 Feet

		From		To	
10 5/8	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+18"	120

PERFORATIONS:
Type of perforation: mill slot
Size of perforation: 3/16x3
From 100 Feet To 120 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal	0	to	100		
☒ Neat Cement	0	to	20	☐ Pumped	☒ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	20	to	100	☐ Pumped	☒ Poured
☒ Bentonite Grout	~~20~~	to	~~100~~	☐ Pumped	☒ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:					
☒ Gravel Pack [> 0.2 in.]	100	to	120	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 18 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
+100		5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Alternative Drilling Co LLC (Contractor)
Address P.O. Box 281166, Lamoille, NV 89828 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* 73955
Nevada well driller's license number as issued by the 2465
Signed: [signature] (By driller performing actual drilling on site or contractor)
9-11-13

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY